

CSA Group Bayern GmbH - Straubinger Straße 100 - 94447 Plattling

Lm-therm Elektrotechnik AG

Sulzbachstr. 15 94501 Aldersbach

Ihr Zeichen

Unser Zeichen MB/HG Telefon 09931 9836-232 Datum 08.09.2025

Statement according to Environmental tests on Control cabinet heaters

To whom it may concern, the Control cabinet heaters

"Wadi-IP65 - 180W,250W,500W Wadi-LH-IP65 - 250W, 380W P-85 - 400W,250W,150W,100W"

were tested according to following standards

and the tests are documented in test report 80249837-00 Rev_1.

Standards

IEC 60529: 2013 Edition 2.2 + COR2:2015 + AMD2 COR1:2019

(Protection against access to hazardous parts and solid foreign objects-IP6X)

IEC 60529: 2013 Edition 2.2 + COR2:2015 + AMD2 COR1:2019

(Water protection - IPX5)

IEC 60335-1:2020, 16.3 and 29

(Electric strength, Clearances and Creepage distances Test evaluation after IPX5)

END OF STATEMENT

Date: 08 September 2025	
Assessed by	Checked by
Michael Maulbetsch Team Lead Environmental	Heide Gruber Senior Project Engineer